



## **Laboratory for Fire Safety**

*Classification of the fire resistance in accordance with  
EN\_13501-2:2023 of a sandwich panel wall,  
SAB\_WB120.1000 FR*

*Classification report*

## Laboratory for Fire Safety

*Classification of the fire resistance in accordance with  
EN\_13501-2:2023 of a sandwich panel wall,  
SAB\_WB120.1000 FR*

### Classification report

|                   |                                                                                                 |
|-------------------|-------------------------------------------------------------------------------------------------|
| Client            | SAB-Profiel B.V.<br>P.O. Box 97<br>3400 AB IJsselstein<br>The Netherlands                       |
| Prepared by       | Peutz bv<br>Lindenlaan 41<br>NL-6584 AC Molenhoek<br>Postbus 66<br>NL-6585 ZH Mook<br>Nederland |
| Notified body no. | NB 2264                                                                                         |
| Product name      | <b>Sandwich panel wall, SAB WB120.1000 FR</b>                                                   |
| Report number     | YA 3161-1E-RA-001                                                                               |
| Date of issue     | 22 November 2024                                                                                |
| Reference         | RO/RO//YA 3161-1E-RA-001                                                                        |
| Responsible       | R.R.H. Okkersen, BSc.                                                                           |
| Author            | R.R.H. Okkersen, BSc.<br>0031 85 8228618<br>r.okkersen@peutz.nl                                 |



This report consists of 10 pages and an Appendix containing 5 pages and can only be used and reproduced in its entirety.

## Table of Contents

|          |                                                |           |
|----------|------------------------------------------------|-----------|
| <b>1</b> | <b>Introduction</b>                            | <b>4</b>  |
| <b>2</b> | <b>Details of the classified system</b>        | <b>5</b>  |
| 2.1      | General                                        | 5         |
| 2.2      | Product description                            | 5         |
| <b>3</b> | <b>Data to support the classification</b>      | <b>7</b>  |
| 3.1      | Report                                         | 7         |
| 3.2      | Results                                        | 7         |
| <b>4</b> | <b>Classification and field of application</b> | <b>8</b>  |
| 4.1      | Reference of the classification                | 8         |
| 4.2      | Classification                                 | 8         |
| 4.3      | Field of application                           | 8         |
| 4.3.1    | General                                        | 8         |
| 4.3.2    | Extension of width                             | 8         |
| 4.3.3    | Extension of height                            | 9         |
| 4.3.4    | Supporting constructions                       | 9         |
| <b>5</b> | <b>Limitations</b>                             | <b>10</b> |

## 1 Introduction

This classification report defines the fire resistance classification which is assigned to a sandwich panel wall, heated according to the standard fire curve, all this in accordance with the procedures described in EN 13501-2:2023, further referenced as EN 13501-2.



For performing measurements, the Laboratory for Fire Safety of Peutz bv is recognized by the Dutch Accreditation Body RvA..

The RvA is member of the **EA MLA** (European Accreditation Organisation MultiLateral Agreement). [www.european-accreditation.org](http://www.european-accreditation.org)

*EA: "Certificates and reports issued by bodies accreditatie by MLA and MRA members are considered to have the same degree of credibility, and are accepted in MLA and MRA countries".*

## 2 Details of the classified system

### 2.1 General

The system, a sandwich panel wall, is defined as an external wall as meant in EN 13501-2 chapter 7.5.3.

The wall has an asymmetrical construction.

### 2.2 Product description

The system, a sandwich panel wall, is fully described in the test report. See also the Appendix.

The test frame consists of a steel frame with heat-resistant concrete elements inside. The installation opening of the test frame is 4.05 m × 3.00 m. A supporting construction is built in the test frame.

An opening is created of 3.0 x 3.0 m (w x h). In this opening three SAB WB120.1000 FR sandwich panels are mounted (with a PIR core material), vertically mounted. The sandwich panels have a dimension of:

- length 3000 mm;
- width 1000 mm;
- thickness 120 mm.

The sandwich panel wall consists of 3 sandwich panels, (3 x 1000 mm) only the noggin was cut of the panels at both edges. The sandwich panels consists of coil coated galvanized steel plates (thickness outer plate 0.50 mm, thickness inner plate 0.40 mm) with a PIR core (thickness 120 mm, 40 kg/m<sup>3</sup>). A standard sealant for air tightness (Panelseal) is factory applied in the joint of the sandwich panels.

The panels are fixed with steel angles (50 x 100 x 1.5 mm) to the supporting construction with plugs (Fisher S 8 x 40 mm) and screws (Fabory Chipboardscrew CSK 6 x 60 mm) c.t.c. 340 mm and to the sandwich panels with self drilling screws (Roymans 6.3 x 22 mm) c.t.c. 250 mm. Sealant (PFC Corofil Firestop) is used between the steel angels and the sandwich panels. A steel U-profile (50 x 120 x 0.7 mm) is fixed with self drilling screws (Roymans 6.3 x 22 mm) c.t.c. 250 mm on the edge of the sandwich panel at the free edge.

The opening between the sandwich panels and the supporting construction is filled with Rockwool (Rocksono Base). On one side is a free edge, this is filled with Rockwool (Rocksono Base, thickness 40 mm).

The materials used are mentioned in the tables below.

## t2.1 Construction materials

| Material                                        | Dimensions / specifications                    |
|-------------------------------------------------|------------------------------------------------|
| Outer coil coated galvanized steel plate, white | Thickness 0.50 mm                              |
| Core material, PIR                              | Thickness 120 mm, density 40 kg/m <sup>3</sup> |
| Sealant for air tightness                       | Type Panelseal                                 |
| Inner coil coated galvanized steel plate, white | Thickness 0.40 mm                              |

## t2.2 Fixing materials

| Material                        | Dimensions / specifications         |
|---------------------------------|-------------------------------------|
| Plug                            | Fisher S 8 x 40 mm                  |
| Screw                           | Fabory Chipboardscrew CSK 6 x 60 mm |
| Self drilling steel plate screw | Roymans 6.3 x 22 mm                 |
| Steel angles                    | 50 x 100 x 1.5 mm                   |
| Steel U-profile                 | 50 x 120 x 50, thickness 0.7 mm     |
| Sealant                         | PFC Corofil Firestop                |

## t2.3 Finishing materials

| Material               | Dimensions / specifications                   |
|------------------------|-----------------------------------------------|
| Rockwool Rocksono Base | Thickness 40 mm, density 35 kg/m <sup>3</sup> |

## 3 Data to support the classification

### 3.1 Report

The classification is based on the report mentioned in Table 3.1. The client has stated that the report provided may be used for this classification report.

#### t3.1 Report used for classification

| Name of the laboratory | Name client      | Number and date of the test report       | Method         |
|------------------------|------------------|------------------------------------------|----------------|
| Peutz bv               | SAB Profiel B.V. | Y 3161-3E-RA-002 dated November 22, 2024 | EN 1363-1:2020 |
|                        |                  |                                          | EN 1363-2:1999 |
|                        |                  |                                          | EN 1364-1:2015 |

### 3.2 Results

The test specimen was heated using the standard heating curve as defined in EN 1363-1. The sandwich panel wall was heated from the outside face.

Table 3.2 shows the time of failure ('fail') with respect to the relevant criteria or the finished test time ('pass') when the relevant criteria were not exceeded during the test. The elapsed time is the time in whole minutes that have elapsed since the commencement of the test.

After 72 minutes the test in consultation with the client is ended.

#### t3.2 Results fire resistance test

| Assessment criterion                              | Elapsed time | Pass / Fail |
|---------------------------------------------------|--------------|-------------|
| Integrity (E)                                     |              |             |
| – no flames more than 10 s continuously visible   | 72 minutes   | pass        |
| – no glowing or burning of the cotton pad         | 72 minutes   | pass        |
| – no gap gauges into the furnace                  | 72 minutes   | pass        |
| Insulation (I)                                    |              |             |
| – increase of average temperature less than 140°C | 41 minutes   | fail        |
| – increase of maximum temperature less than 180°C | 26 minutes   | fail        |
| Radiation (W)                                     |              |             |
| – 15 kW/m <sup>2</sup> not exceeded               | 72 minutes   | pass        |
| Deformation of the wall no more than 100 mm       | 64 minutes   | fail        |

## 4 Classification and field of application

### 4.1 Reference of the classification

This classification is performed in accordance with paragraph 7.5.3 of EN 13501-2.

### 4.2 Classification

The system, an external wall, is classified according to the following combinations of assessment criteria and classes.

#### **Classification of the fire resistance:**

**EI 20(o→i)**  
**EW 60 (o→i)**  
**E 60 (o→i)**

### 4.3 Field of application

#### 4.3.1 General

The classification is valid for constructions that are identical in detail to the construction described in the test report. In addition, within the field of direct application as defined in the test standard(s) presented in Table 3.1, one or more of the modifications of the tested construction shown below are permitted, provided that the construction achieves at least the same rigidity and stability as the tested construction.

In all cases, the following adjustments are possible:

- decrease in height of the wall;
- increase in thickness of the wall, minimum thickness 120 mm;
- increase in the thickness of component materials;
- decrease in linear dimensions of boards or panels but not thickness;
- decrease in distance of fixing centres, maximum distance 250 mm c.t.c.;
- increase in the number of vertical joints, of the type tested.

#### 4.3.2 Extension of width

Since the construction has been tested with a width of 3.0 m (minimum 2.8 m) and one free edge, an identical construction with a larger width may be used.

Since the measured heat radiation is less than 6 kW/m<sup>2</sup>, an increase in width of an identical construction is also allowed for EW classification.



#### 4.3.3 Extension of height

Since the construction is tested with a height of 3.0 m and the deflection perpendicular to the wall was less than 100 mm the construction may be increased to a height of 4.0 m, provided that the expansion allowances are increased pro-rata.

Since the measured heat radiation is less than  $6 \text{ kW/m}^2$ , an increase in height to 4.0 m of an identical construction is also allowed for EW classification.

#### 4.3.4 Supporting constructions


The result is applicable to any other supporting construction of the same type (rigid) that has the same or a greater classified fire resistance (thicker, denser, as appropriate) than the one used in the test and the same vertical orientation, i.e.:

- only vertical since the element is tested with the standard supporting construction fixed along the vertical edge.

## 5 Limitations

This classification document does not represent type approval or certification of this product.

Haps,





H.H.A. Leenders, BSc.  
Head of Laboratory for Fire Safety





D.J. den Boer, BSc.  
Management

This report consists of:  
10 page's with 1 Appendix of 5 pages









## Stuklijst:

- 1) PIR-foam
- 2) Inner sheet 0.40 mm
- 3) Outer sheet 0.50 mm
- 4) Fixener: Roymans 6.3 x 22 mm
- 5) L-profile 50 x 100 x 1.50 mm / U-profile 50 x 120 x 50 mm, thickness 0.70 mm
- 6) Concrete frame
- 7) Rockwool insulation
- 8) Firestop acoustic intumescent sealant
- 9) Plug Fischer S8 x 40 mm, fixener Fabory Chipboardscrew CSK 6 x 60 mm
- 10) Standard factory applied sealant for air tightness, Panelseal

Sensitivity: general